

EOM

ENGINEERING OPERATION& MAINTENANCE MANUAL

PS220/PS230 Bolted Metal Pump







Where Innovation Flows







Copyright

Copyright 2018 PSG[®], a Dover Company. All rights reserved.

PSG reserves the right to modify the information and illustrations in this document without prior notice. The product described in this document is furnished under a license agreement or nondisclosure agreement. No part of this document may be reproduced, stored in a retrieval system, or transmitted in any form or any means electronic or mechanical, including photocopying and recording, without the written permission of PSG, a Dover Company, except as described by the terms of those agreements.

This is a non-contractual document.

Trademarks

PSG and the PSG logo are registered trademarks of PSG. Wilden® is a registered trademark of PSG California LLC. Pro-Flo® SHIFT, Pro-Flo®, and Wil-Flex® are registered trademarks of PSG California LLC. Chem-Fuse™, Pure-Fuse™, Saniflex™, and Bunalast™ are trademarks of PSG California LLC.

All trademarks, names, logos and service marks (collectively "trademarks") in this document are registered and unregistered trademarks of their respective owners. Nothing contained in this document should be construed as granting any license or right to use any trademark without the prior written permission of the trademark owner.

Warranty

Each and every product manufactured by Wilden is built to meet the highest standards of quality. Every pump is functionally tested to ensure integrity of operation. Wilden warrants that pumps, accessories and parts manufactured or supplied by it to be free from defects in material and workmanship for a period of five (5) years from date of installation or six (6) years from date of manufacture, whichever comes first.

For more information, and to register your Wilden pump for warranty, please visit https://www.psgdover.com/wilden/support/warranty-registration.

Certifications









CONTENTS

SECTION 1: Precautions – Read First!	4
SECTION 2: Wilden Pump Designation System	5
SECTION 3: How It Works	6
SECTION 4: Dimensional Drawings	7
SECTION 5: Performance	
PS220/PS230 Metal Rubber-Fitted	9
PS220/PS230 Metal EZ-Install TPE-Fitted	9
PS220/PS230 Metal Full-Stroke PTFE-Fitted	10
Suction Lift Capability	11
SECTION 6: Suggested Installation, Operation, Maintenance, and Troubleshooting	12
SECTION 7: Disassembly/Reassembly	15
Pump Disassembly	15
Air Valve/Center Section Disassembly	18
Single Point Exhaust	20
Reassembly Hints and Tips	
SECTION 8: Exploded View and Parts List	22
SECTION 9: Elastomer Options	24



WILDEN

SECTION 1

PRECAUTIONS - READ FIRST!



WARNING: Always wear safety glasses when operating a pump to avoid eye injury. If diaphragm rupture occurs, material being pumped may be forced out of the air exhaust.



CAUTION: Do not apply compressed air to the exhaust port – pump will not function.



CAUTION: Do not over-lubricate air supply– excess lubrication will reduce pump performance. Pump is pre-lubed.



TEMPERATURE LIMITS:

-29°C to 82°C	-20°F to 180°F
-12°C to 82°C	10°F to 180°F
-40°C to 130°C	-40°F to 266°F
-40°C to 82°C	-40°F to 180°F
-18°C to 93°C	0°F to 200°F
-51°C to 138°C	-60°F to 280°F
-18°C to 93°C	0°F to 200°F
-7°C to 107°C	45°F to 225°F
0°C to 79°C	32°F to 175°F
-12°C to 66°C	10°F to 150°F
-12°C to 107°C	10°F to 225°F
-29°C to 104°C	-20°F to 220°F
4°C to 137°C	40°F to 280°F
4°C to 93°C	40°F to 200°F
4°C to 104°C	40°F to 220°F
-40°C to 177°C	-40°F to 350°F
-40°C to 107°C	-40°F to 225°F
	-12°C to 82°C -40°C to 130°C -40°C to 82°C -18°C to 93°C -51°C to 138°C -7°C to 107°C 0°C to 79°C -12°C to 66°C -12°C to 107°C -29°C to 104°C 4°C to 137°C 4°C to 93°C 4°C to 104°C -40°C to 177°C

 $^{^*4^{\}circ}\text{C}$ to 149°C (40°F to 300°F) - 13 mm (1/2") & 25 mm (1") models only.

NOTE: Not all materials are available for all models. See "Wilden Pump Designation System" for material options for your pump.

NOTE: UL-listed configured pumps have the following temperature limits: UL 79 Buna-N =12.2°C to 52°C (10°F to 125°F).



CAUTION: When choosing pump materials, be sure to check the temperature limits for all wetted components. Example: FKM has a maximum limit of 177°C (350°F), but polypropylene has a maximum limit of only 79°C (175°F).



CAUTION: Maximum temperature limits are based on mechanical stress only. Certain chemicals will reduce maximum safe operating temperatures significantly. Consult the Chemical Resistance Guide for chemical compatibility and temperature limits



CAUTION: All Wilden pumps are capable of passing solids. Use a strainer on the pump intake to ensure that the pump's rated solids capacity is not exceeded.



CAUTION: Do not exceed 8.6 bar (125 psig) air supply pressure. For UL-listed pumps, do not exceed 3.4 bar (50 psig) air supply pressure.



CAUTION: Do not exceed 82°C (180°F) air inlet temperature for all models.



CAUTION: The process fluid and cleaning fluids must be compatible chemically with all wetted pump components.



CAUTION: Before attempting any maintenance or repair, disconnect the compressed air line to the pump and allow all air pressure to bleed from the pump. Disconnect all intake,

discharge, and air lines. Drain the pump by turning it upside down and allowing any fluid to flow into a suitable container. Be aware of any hazardous effects of contact with your process fluid.



CAUTION: Thoroughly flush pumps before installing them into process lines. Clean and/or sanitize FDA- and USDA- approved pumps before using them.



CAUTION: Before attaching the air line to the pump, blow out the air line for 10 to 20 seconds to make sure all pipeline debris is clear. Use an in-line air filter. A 5μ (micron) air filter is recommended.



CAUTION: Pro-Flo SHIFT is available in both single-point exhaust (submersible) and standard (non-submersible) options. Do not use standard Pro-Flo SHIFT models in submersible applications.



CAUTION: For UL-listed pumps, all pipe connections are to be made using UL classified gasoline-resistant pipe compound.



CAUTION: For UL-listed pumps, all installations must conform to NFPA 30, NFPA 30A and other applicable codes.




CAUTION: For UL-listed pumps, air exhaust port is to be connected to pipe or tubing to be routed outdoors or other location determined to be equivalent.



CAUTION: For UL-listed pumps, pump is to be grounded using the jam-nut located at the top of the long vertical carriage bolt. The ground connection is marked with a tag having the grounding symbol.



CAUTION: Before installation, tighten all hardware.



- NOTE: When installing PTFE diaphragms, it is important to tighten outer pistons simultaneously (turning in opposite directions) to ensure tight fit. (See "Maximum Torque Specifications").
- NOTE: Some PTFE-fitted pumps come standard from the factory with expanded PTFE gaskets installed in the diaphragm bead of the liquid chamber. PTFE gaskets cannot be re-used.
- **NOTE:** In the event of a power failure, close the shut-off valve if you do not want the pump to restart when the power returns.
- NOTE: The Safety Supplement document is a part of the manual. Please refer to the Safety Supplement document for a complete list of safety considerations including considerations for safe operation and maintenance of pumps marked for ATEX environments before starting the pump.




WARNING: This product can expose you to chemicals including Nickel, Chromium, Cadmium, or Cobalt, which are known to the State of California to cause cancer and/or birth defects or other reproductive harm. For more information, go to www.P65Warnings.ca.gov.





WILDEN PUMP DESIGNATION SYSTEM



MATERIAL CODES

MODEL

XPS220 = PRO-FLO® SHIFT ATEX THREADED PORTS

XPS230 = PRO-FLO® SHIFT ATEX FLANGED PORTS

PS220 = PRO-FLO® SHIFT THREADED PORTS

PS230 = PRO-FLO® SHIFT

FLANGED PORTS

WETTED PATH

A = AI UMINUM H = ALLOY C

S = STAINLESS STEEL

W = DUCTILE IRON

OUTER PISTON

A = ALUMINUM

H = ALLOY C

S = STAINLESS STEEL W = DUCTILE IRON

Z = NO OUTER PISTON

CENTER SECTION

AA = ALUMINUM

AIR VALVE

A = ALUMINUM

DIAPHRAGMS

BLL = BUNALAST™ IPD (BLACK)

BNS = BUNA-N (RED DOT) EPS = EPDM (BLUE DOT)

FSL = FULL-STROKE SANITARY

SANIFLEX™, IPD [HYTREL®

(CREAM)]

FSS = SANIFLEX™ [HYTREL®

(CREAM)]

NES = NEOPRENE (GREEN DOT) SSL = FULL-STROKE SANIFLEXTM

IPD [HYTREL® (CREAM)]

TSS = FULL-STROKE PTFE W/SANIFLEX™ BACK-UP

TWS = FULL-STROKE PTFE

W/WIL-FLEX® BACK-UP VTS = FKM (WHITE DOT)

WFS = WIL-FLEX® [SANTOPRENE®

(THREE BLACK DOTS)]

WWL= WIL-FLEX® IPD

ISANTOPRENE® (THREE

BLACK DOTS)]

VALVE BALLS

BN = BUNA-N (RED DOT) EP = EPDM (BLUE DOT)

FS = SANIFLEX™ [HYTREL®

(CREAM)]

NE = NEOPRÊNE (GREEN DOT)

TF = PTFE (WHITE)

VT = FKM (WHITE DOT)

WF = WIL-FLEX® [SANTOPRENE® (THREE BLACK DOTS)]

VALVE SEATS

A = ALUMINUM

H = ALLOY C

M = MILD STEEL

S = STAINLESS STEEL

VALVE SEAT O-RINGS

BN = BUNA-N (RED DOT)

EP = EPDM (BLUE DOT)

FS = SANIFLEX™ [HYTREL® (CREAM)]

NE = NEOPRENE (GREEN DOT)

TF = PTFE (WHITE)

VT = FKM (WHITE DOT)

WF = WIL-FLEX® [SANTOPRENE® (THREE BLACK DOTS)]

SPECIALTY CODES

0014 BSPT

0100 Wil-Gard 110V

0102 Wil-Gard sensor wire ONLY 0103 Wil-Gard 220V

0319 Single-port exhaust, BSPT

0320 Single-port exhaust

0480 Pump cycle monitor (sensor & wires)

0483 Pump cycle monitor (module, sensor & wires) 0485 Pump cycle monitor (module, sensor & wires), DIN flange

0492 U.L. Approved, Side-ported (1" inlet and discharge manifolds) 0493 U.L. Approved, Center Ported NPT

(Inlet facing air inlet, discharge facing exhaust)

0494 U.L. Approved, Center Ported NPT

(Inlet facing exhaust, discharge facing air inlet)

0504 DIN flange 0677 25 mm (1") NPT center-ported inlet and discharge manifold

0678 25 mm (1") BSPT center-ported inlet and discharge manifold 0687 25 mm (1") NPT center-ported inlet and discharge manifold,

Submersible Center Section 0688 25 mm (1") BSPT center-ported inlet and discharge manifold,

Submersible Center Section 0695 19 mm (3/4") NPT center-ported discharge manifold (inlet facing air inlet, discharge facing exhaust)

0696 19 mm (3/4") BSPT center-ported discharge manifold (inlet facing air inlet, discharge facing exhaust)

0697 19 mm (3/4") NPT center-ported discharge manifold (inlet facing exhaust, discharge facing air inlet)

0698 19 mm (3/4") BSPT center-ported discharge manifold (inlet facing exhaust, discharge facing air inlet)

0735 19 mm (3/4") NPT center-ported discharge manifold, Submersible Center Section (inlet facing air inlet, discharge facing exhaust)

0736 19 mm (3/4") BSPT center-ported discharge manifold, Submersible Center Section (inlet facing air inlet, discharge facing exhaust)

19 mm (3/4") NPT center-ported discharge manifold, Submersible Center Section (inlet facing exhaust, discharge facing air inlet)

0738 19 mm (3/4") BSPT center-ported discharge manifold, Submersible Center Section (inlet facing exhaust, discharge facing air inlet)

V0651 Vertically-ported discharge, NPT, includes pipe plug (ISD) V0652 Vertically-ported discharge, BSPT, includes pipe plug (ISD)

V0677 Inlet, center, and vertical-ported discharge, NPT, includes

pipe plug (ISD) V0678 Inlet, center, and vertical-ported discharge, BSPT, includes pipe plug (ISD)

NOTE: Most elastomeric materials use colored dots for identification

NOTE: Not all models are available with all material options

! NOTE: The Wilden UL 79-listed products covered by this manual are PS220 models and are defined by Specialty Codes. All materials may not be available for UL-Listed pumps. Wilden UL-Listed pumps have been evaluated for use at a 25°C (77°F) ambient temperature with a maximum inlet pressure of 3.4 bar (50 psig).

! NOTE: "V#### where "V" in front of 4 digit specialty code denotes vertical port opening for ISD mounting.

NOTE: ZGS diaphragm material previously known as Geolast® has been replaced with Bunalast™

WII -11560-F-09 5





HOW IT WORKS - AIR-OPERATED DOUBLE-DIAPHRAGM PUMP

The Wilden diaphragm pump is an air-operated, positive displacement, self-priming pump. These drawings show flow pattern through the pump upon its initial stroke. It is assumed the pump has no fluid in it prior to its initial stroke.




FIGURE 1 The air valve directs pressurized air to the back side of diaphragm A. The compressed air is applied directly to the liquid column separated by elastomeric diaphragms. The diaphragm acts as a separation membrane between the compressed air and liquid; a balanced load removes mechanical stress from the diaphragm. The compressed air moves the diaphragm away from the center of the pump. The opposite diaphragm is pulled in by the shaft connected to the pressurized diaphragm. Diaphragm B is on its suction stroke; air behind the diaphragm has been forced out to atmosphere through the exhaust port of the pump. The movement of diaphragm B toward the center of the pump creates a vacuum within chamber B. Atmospheric pressure forces fluid into the inlet manifold forcing the inlet valve ball off its seat. Liquid is free to move past the inlet valve ball and fill the liquid chamber (see shaded




FIGURE 2 When the pressurized diaphragm, diaphragm A, reaches the limit of its discharge stroke, the air valve redirects pressurized air to the back side of diaphragm B. The pressurized air forces diaphragm B away from the center while pulling diaphragm A to the center. Diaphragm B is now on its discharge stroke. Diaphragm B forces the inlet valve ball onto its seat due to the hydraulic forces developed in the liquid chamber and manifold of the pump. These same hydraulic forces lift the discharge valve ball off its seat, while the opposite discharge valve ball is forced onto its seat, forcing fluid to flow through the pump discharge. The movement of diaphragm A toward the center of the pump creates a vacuum within liquid chamber A. Atmospheric pressure forces fluid into the inlet manifold of the pump. The inlet valve ball is forced off its seat allowing the fluid being pumped to fill the liquid chamber.





FIGURE 3 At completion of the stroke, the air valve again redirects air to the back side of diaphragm A, which starts diaphragm B on its exhaust stroke. As the pump reaches its original starting point, each diaphragm has gone through one exhaust and one discharge stroke. This constitutes one complete pumping cycle. The pump may take several cycles to completely prime depending on the conditions of the application.

HOW IT WORKS – AIR DISTRIBUTION SYSTEM




The heart of the patented Pro-Flo® SHIFT Air Distribution System (ADS) is the air valve assembly. The air valve design incorporates an unbalanced spool with the small end of the spool being pressurized continuously while the large end of the spool is alternately pressurized, then exhausted to move the spool. The air valve spool directs pressurized air to one chamber while exhausting the other. The air forces the main shaft/diaphragm assembly to move to one side – discharging liquid on that side and pulling liquid in on the other side. When the shaft reaches the end of the stroke, the inner piston actuates the pilot spool, which controls the air to the large end of the air valve spool. The repositioning of the air valve spool routes the air to the other air chamber. The air control spool allows air to flow freely into the air chamber for the majority of each pump stroke, but it significantly restricts the flow of air into the air chamber when activated by the inner piston near the end of each stroke.






DIMENSIONAL DRAWING

PS220 METAL




1" BSPT (FNPT) LIQUID INLET




DIMENSIONS


ITEM	METRIC (mm)	STANDARD (inch)
Α	361	14.2
В	36	1.4
С	163	6.4
D	254	10.0
Е	287	11.3
F	56	2.2
G	417	16.4
Н	71	2.8
J	140	5.5
K	155	6.1
L	206	8.1
М	173	6.8
N	104	4.1
Р	127	5.0
R	10	0.4
		I W0364 REV A

LW0364 REV. A



PS220 METAL - CENTER PORT





DIMENSIONS

ITEM	METRIC (mm)	STANDARD (inch)
Α	422	16.6
В	36	1.4
С	163	6.4
D	254	10.0
Е	287	11.3
F 33		1.3
G	417	16.4
Η	71	2.8
J	140	5.5
K	155	6.1
Г	206	8.1
М	173	6.8
N 104		4.1
Р	127	5.0
R	10	0.4


LW0365 REV. A







DIMENSIONAL DRAWING

PS230 STAINLESS STEEL & ALLOY C









DIMENSIONS

ITEM	METRIC (mm)	STANDARD (inch)
Α	373	14.7
В	69	2.7
С	195	7.6
D	287	11.3
E F	340	13.4
	343	13.5
G	71	2.8
Н	417	16.4
J	71	2.8
K	140	5.5
L	188	7.4
М	206	8.1
N	173	6.8
P 104		4.1
R	127	5.0
S 10		0.4
T 203		8.0
DIN (mm)		ANSI (Inch)
U	85 DIA.	3.1 DIA.
V	115 DIA.	4.3 DIA.
W	14 DIA.	0.6 DIA.
		LW0366 DEV C

LW0366 REV. C





PERFORMANCE

PS220/PS230 METAL RUBBER-FITTED

Ship Weight	Aluminum 19 kg (41 lb)
. •	Ductile Iron 29 kg (64 lb)
316 St	tainless Steel 31 kg (68 lb)
	Alloy C 36 kg (80 lb)
Air Inlet	1/2 ["]
Inlet	25 mm (1")
Outlet	25 mm (1")
Suction Lift	6.9 m Dry (22.7')
	9.0 m Wet (29.5')
Disp. Per Stroke1	0.30 L (0.08 gal)
Max. Flow Rate	204 lpm (54 gpm)
Max. Size Solids	6.4 mm (1/4")
	,

¹Displacement per stroke was calculated at 4.8 bar (70 psig) air inlet pressure against a 2.1 bar (30 psig) head pressure.

Example: To pump 140 lpm (37 gpm) against a discharge pressure head of 2.8 bar (40 psig) requires 5.5 bar (80 psig) and 60 Nm³/h (38 scfm) air consumption.

BAR FEET PSIG 300 10 [17] 7) |**20** [34] |**30** [51] 120 275 8 AIR CONSUMPTION 250 (SCFM) [Nm³/h] 40 [68] 7 100 225 **50** [85] Discharge Pressure 6 200 80 175 5 150 60 4 125 3 100 40 75 2 50 20 1-25 0 0 0 **GPM** 40 50 10 30 60 [LPM] [38] [76] [114] [151] [189] [227] **Water Discharge Flow Rates**


Flow rates indicated on chart were determined by pumping water. For optimum life and performance, pumps should be specified so that daily operation parameters will fall in the center of the pump's performance curve.

Caution: Do not exceed 8.6 bar (125 psig) air supply pressure. For UL-listed pumps, do not exceed 3.4 bar (50 psig) air supply pressure.

PS220/PS230 METAL TPE-FITTED

Ship Weight.	
	Ductile Iron 29 kg (64 lb)
	316 Stainless Steel 31 kg (68 lb)
	Alloy C 36 kg (80 lb)
Air Inlet	1/2"
Inlet	25 mm (1")
	25 mm (1")
Suction Lift	5.9 m Dry (19.3')
	9.0 m Wet (29.5')
Disp. Per Str	oke ¹ 0.26 L (0.07 gal)
Max. Flow Ra	ate212 lpm (56 gpm)
Max. Size So	lids6.4 mm (1/4")

¹Displacement per stroke was calculated at 4.8 bar (70 psig) air inlet pressure against a 2.1 bar (30 psig) head pressure.



Flow rates indicated on chart were determined by pumping water. For optimum life and performance, pumps should be specified so that daily operation parameters will fall in the center of the pump's performance curve.

Example: To pump 144 lpm (38 gpm) against a discharge head of 2.8 bar (40 psig) requires 5.5 bar (80 psig) and 63 Nm³/h (40 scfm) air consumption.

Caution: Do not exceed 8.6 bar (125 psig) air supply pressure. For UL-listed pumps, do not exceed 3.4 bar (50 psig) air supply pressure.






PERFORMANCE

PS220/PS230 METAL FULL-STROKE PTFE-FITTED

Ship Weight	Aluminum 19 kg (41 lb)
	Ductile Iron 29 kg (64 lb)
316 St	ainless Steel 31 kg (68 lb)
	Alloy C 36 kg (80 lb)
Air Inlet	1/2"
Inlet	25 mm (1")
Outlet	25 mm (1")
Suction Lift	5.2 m Dry (17.0')
	9.0 m Wet (29.5')
Disp. Per Stroke1	0.30 L (0.08 gal)
	197 lpm (52 gpm)
Max. Size Solids	6.4 mm (1/4")

¹Displacement per stroke was calculated at 4.8 bar (70 psig) air inlet pressure against a 2.1 bar (30 psig) head pressure.

Example: To pump 83.3 lpm (22 gpm) against a discharge head of 2.8 bar (40 psig) requires 4.1 bar (60 psig) and 36 Nm³/h (23 scfm) air consumption.



Flow rates indicated on chart were determined by pumping water. For optimum life and performance, pumps should be specified so that daily operation parameters will fall in the center of the pump's performance curve.

Caution: Do not exceed 8.6 bar (125 psig) air supply pressure. For UL-listed pumps, do not exceed 3.4 bar (50 psig) air supply pressure.






SUCTION LIFT CAPABILITY

PS220/PS230 METAL SUCTION LIFT CAPABILITY

Suction-lift curves are calibrated for pumps operating at 305 m (1,000') above sea level. This chart is meant to be a guide only. There are many variables that can affect your pump's operating characteristics. The number of intake and discharge elbows, viscosity of pumping fluid, elevation (atmospheric pressure) and pipe friction loss all affect the amount of suction lift your pump will attain.





SUGGESTED INSTALLATION, OPERATION, MAINTENANCE AND TROUBLESHOOTING

W ilden pumps are designed to meet the performance requirements of even the most demanding pumping applications. They have been designed and manufactured to the highest standards and are available in a variety of liquid path materials to meet your chemical resistance needs. Refer to "Performance" for an in-depth analysis of the performance characteristics of your pump. Wilden offers the widest variety of elastomer options in the industry to satisfy temperature, chemical compatibility, abrasion resistance and flex concerns.

The suction pipe size should be at least equal to or larger than the diameter size of the suction inlet on your Wilden pump. The suction hose must be a non-collapsible, reinforced type because these pumps are capable of pulling a high vacuum. Discharge piping should also be equal to or larger than the diameter of the pump discharge, which will help reduce friction losses.



CAUTION: All fittings and connections must be airtight. Otherwise, pump suction capability will be reduced or lost.

Months of careful planning, study and selection efforts can result in unsatisfactory pump performance if installation details are left to chance. You can avoid premature failure and long-term dissatisfaction by exercising reasonable care throughout the installation process.

Location

Noise, safety and other logistical factors usually dictate where equipment will be situated on the production floor. Multiple installations with conflicting requirements can result in congestion of utility areas, leaving few choices for additional pumps.

Within the framework of these and other existing conditions, locate every pump in such a way that the following six key factors are balanced against each other to maximum advantage:

- Access: First, the location should be accessible. If it's easy to
 reach the pump, maintenance personnel will be able to perform
 routine inspections and adjustments more easily. If major repairs
 become necessary, ease of access can play a key role in speeding
 the repair process and reducing total downtime.
- Air Supply: Every pump location should have an air line large enough to supply the volume of air necessary to achieve the desired pumping rate. For best results, the pumps should use a 5µ (micron) air filter, needle valve and regulator. The use of an air filter before the pump will ensure that the majority of any pipeline contaminants will be eliminated.
- Solenoid Operation: When operation is controlled by a solenoid valve in the air line, three-way valves should be used. This valve allows trapped air between the valve and the pump to bleed off, which improves pump performance. You can estimate pumping volume by counting the number of strokes per minute, and then multiplying that figure by the displacement per stroke.
- Muffler: Using the standard Wilden muffler, sound levels are reduced below OSHA specifications. You can use other mufflers to reduce sound levels farther, but they usually reduce pump performance.
- Elevation: Selecting a site that is well within the pump's dynamic lift capability will assure that loss-of-prime issues will be eliminated. In addition, pump efficiency can be adversely affected if proper attention is not given to site location.
- Piping: Final determination of the pump site should not be made until the piping challenges of each possible location have been evaluated. The impact of current and future installations should be considered ahead of time to make sure that inadvertent restrictions are not created for any remaining sites.

 For UL-listed pumps, all installation must conform with NFPA 30, NFPA 30A, and other applicable codes. All pipe connections are to be made using UL-classified gasoline-resistant pipe compound. Exhaust port is to be connected to pipe or tubing to be routed outdoors or other location determined to be equivalent.

The best choice possible will be a site involving the shortest and straightest hook-up of suction and discharge piping. Unnecessary elbows, bends and fittings should be avoided. Pipe sizes should be selected to keep friction losses within practical limits. All piping should be supported independently of the pump. In addition, the piping should be aligned to avoid placing stress on the pump fittings.

Flexible hose can be installed to aid in absorbing the forces created by the natural reciprocating action of the pump. If the pump is to be bolted down to a solid location, a mounting pad placed between the pump and the foundation will assist in minimizing pump vibration. Flexible connections between the pump and rigid piping will also assist in minimizing pump vibration. If quick-closing valves are installed at any point in the discharge system, or if pulsation within a system becomes a problem, a surge suppressor (SD Equalizer) should be installed to protect the pump, piping and gauges from surges and water hammer.

If the pump is to be used in a self-priming application, make sure that all connections are airtight and that the suction lift is within the model's ability.



NOTE: Materials of construction and elastomer material have an effect on suction lift parameters. Please refer to "Performance" for specifics.

When pumps are installed in applications involving flooded suction or suction head pressures, a gate valve should be installed in the suction line to permit closing of the line for pump service.

Pumps in service with a positive suction head are most efficient when inlet pressure is limited to 0.5–0.7 bar (7–10 psig). Premature diaphragm failure may occur if positive suction is 0.7 bar (10 psig) and higher.

Single-Point Exhaust

Pro-Flo SHIFT pumps can be used for submersible applications when using the Pro-Flo SHIFT's single-point exhaust.



CAUTION: All Wilden pumps are capable of passing solids. Use a strainer on the pump intake to ensure that the pump's rated solids capacity is not exceeded.




CAUTION: Do not exceed 8.6 bar (125 psig) air supply pressure. For UL-listed pumps, do not exceed 3.4 bar (50 psig) air supply pressure.





SUGGESTED INSTALLATION, OPERATION, MAINTENANCE AND TROUBLESHOOTING



NOTE: In the event of a power failure, close the shutoff valve if you do not want the pump to restart when the power returns.

Air-Operated Pumps: To stop the pump from operating in an emergency, simply close the shut-off valve (user-supplied) installed in the air supply line. A properly functioning valve will stop the air supply to the pump, therefore stopping output. This shut-off valve should be located far enough away from the pumping equipment such that it can be reached safely in an emergency.

Operation

The Pro-Flo SHIFT pumps are pre-lubricated and do not require inline lubrication. Additional lubrication will not damage the pump. However, if the pump is heavily lubricated by an external source, the pump's internal lubrication maybe washed away. If the pump is then moved to a nonlubricated location, it may need to be disassembled and re-lubricated as described in "Disassembly/ Reassembly".

Pump discharge rate can be controlled by limiting the volume and/or pressure of the air supply to the pump. An air regulator is used to regulate air pressure. A needle valve is used to regulate volume. Pump discharge rate also can be controlled by throttling the pump discharge by partially closing a valve in the discharge line of the pump. This action increases friction loss, which reduces flow rate. (See "Performance") This is useful when the need exists

to control the pump from a remote location. When the pump discharge pressure equals or exceeds the air supply pressure, the pump will stop. No bypass or pressure relief valve is needed, and pump damage will not occur. The pump has reached a "deadhead" situation and can be restarted by reducing the fluid discharge pressure or increasing the air inlet pressure. Wilden Pro-Flo SHIFT pumps run solely on compressed air and do not generate heat. Therefore, your process fluid temperature will not be affected.

Maintenance and Inspections

Because each application is unique, maintenance schedules maybe different for every pump. Frequency of use, line pressure, viscosity and abrasiveness of process fluid all affect the parts life of a Wilden pump. Periodic inspections have been found to offer the best means for preventing unscheduled pump downtime. Personnel familiar with the pump's construction and service should be informed of any abnormalities that are detected during operation.



SUGGESTED INSTALLATION, OPERATION, MAINTENANCE AND TROUBLESHOOTING

Troubleshooting

Pump will not run or runs slowly.

- Remove plug from pilot spool exhaust.
- Ensure that the air inlet pressure is at least 0.4 bar (5 psig)
 above startup pressure and that the differential pressure (the
 difference between air inlet and liquid discharge pressures) is
 not less than 0.7 bar (10 psig).
- Check air inlet filter for debris (see "Suggested Installation, Operation, Maintenance and Troubleshooting").
- Check for extreme air leakage (blow by) that would indicate worn seals/bores in the air valve, pilot spool and main shaft.
- Disassemble the pump and check for obstructions in the air passageways or objects that would obstruct the movement of internal parts.
- 6. Check for sticking ball check valves.
 - If material being pumped is not compatible with pump elastomers, swelling may occur. Replace ball check valves and seals with proper elastomers.
 - Also, as the check valve balls wear out, they become smaller and can become stuck in the seats. In this case, replace balls and seats.
- Check for any broken inner piston that would cause the air valve spool to be unable to shift.

Pump runs, but little or no product flows.

- Check for pump cavitation. Slow pump speed down to allow thick material to flow into liquid chambers.
- 2. Verify that vacuum required to lift liquid is not greater than the vapor pressure of the material being pumped (cavitation).
- 3. Check for sticking ball check valves.
 - If material being pumped is not compatible with pump elastomers, swelling may occur. Replace ball check valves and seals with proper elastomers.
 - Also, as the check valve balls wear out, they become smaller and can become stuck in the seats. In this case, replace balls and seats.

Pump air valve freezes.

- 1. Check for excessive moisture in the compressed air.
 - Either install a dryer or a hot air generator for compressed air
 - Alternatively, you may use coalescing filter to remove the water from the compressed air in some applications.

Air bubbles in pump discharge.

- Check for a ruptured diaphragm.
- Check tightness of outer pistons (see "Disassembly/Reassembly").
- Check tightness of fasteners and integrity of O-rings and seals, especially at intake manifold.
- 4. Ensure pipe connections are airtight.

Product comes out air exhaust.

- 1. Check for a diaphragm rupture.
- 2. Check the tightness of the outer pistons to the shaft.





DISASSEMBLY / REASSEMBLY

PUMP DISASSEMBLY

Tools Required:

- 1/2" Box Wrench
- Two 1" Sockets or Adjustable Wrench
- Adjustable Wrench
- Vise equipped with soft jaws (such as plywood, plastic or other suitable material)



CAUTION: Before attempting any maintenance or repair, disconnect the compressed air line to the pump and allow all air pressure to bleed from the pump. Disconnect all intake, discharge, and air lines. Drain the pump by turning it upside down and allowing any fluid to flow into a suitable container. Be aware of any hazardous effects of contact with your process fluid.

- NOTE: Your specific pump model may vary from the configuration shown; however, pump disassembly procedure will be the same.
- NOTE: Replace worn parts with genuine Wilden parts for reliable performance.



Step 1

Before starting disassembly, mark a line from each liquid chamber to its corresponding air chamber. This line will assist in proper alignment during reassembly.



Step 2

Using an appropriately-sized wrench, remove the discharge manifold from the liquid chambers.



Stan 3

Inspect ball cage area of manifold for excessive wear or damage. Remove the discharge valve balls and valve seats from the liquid chambers, and inspect for nicks, gouges, chemical attack or abrasive wear. Replace worn parts with genuine Wilden parts for reliable performance.








Step 4


Using an appropriately-sized wrench, remove the inlet manifold from the liquid chambers.

NOTE: Inverting the pump will facility removal of the inlet manifold.




Step 5

Inspect ball cage area of manifold for excessive wear or damage. Remove the inlet valve balls, seats and valve seat Orings from the liquid chamber and inlet manifold, inspect for nicks, gouges, chemical attack or abrasive wear. Replace worn parts with genuine Wilden parts for reliable performance.



Step 6

Using a an appropriately-sized wrench, remove the liquid chambers from the center section.



Step 7

The liquid chamber should be removed to expose the diaphragm and outer piston. Rotate center section and remove the opposite liquid chamber.



Step 8

Using two adjustable wrenches or 1" sockets, remove diaphragm assembly from center section assembly.



Step 9

After loosening and removing the outer piston the diaphragm assembly can be disassembled.







Step 10

To remove the diaphragm assembly from shaft, secure shaft with soft jaws (aluminum, plastic, or plywood) to ensure the shaft is not damaged. Using an adjustable wrench, remove the diaphragm assembly from the shaft.



Step 11

Inspect diaphragms, outer and inner pistons for signs of wear. Replace with genuine Wilden parts if necessary.





AIR VALVE / CENTER SECTION DISASSEMBLY

Tools Required:

- 3/16" Hex-Head Wrench
- Snap-Ring Pliers
- O-Ring Pick



CAUTION: Before attempting any maintenance or repair, disconnect the compressed air line to the pump and allow all air pressure to bleed from the pump. Disconnect all intake, discharge, and air lines. Drain the pump by turning it upside down and allowing any fluid to flow into a suitable container. Be aware of any hazardous effects of contact with your process fluid.

NOTE: Replace worn parts with genuine Wilden parts for reliable performance.

NOTE: For pump Air Valves fitted with Pump Cycle Monitor (PCMI) units, if the Set Screw is removed from the Air Valve Spool and/or the Sensor is removed from the Air Valve End Cap, refer to PCMI EOM WIL-19130-E for reassembly instructions.



Step 1

Loosen the air valve bolts utilizing 3/16" hex-head wrench.



Step 2

Remove muffler plate and air valve bolts from air valve assembly exposing muffler gasket for inspection. Replace if necessary.



Stan 3

Lift away air valve assembly and remove air valve gasket for inspection. Replace if necessary.



Step 4

Remove air valve end cap to expose air valve spool by simply lifting up on end cap once air valve bolts are removed.




Step 5

Remove air valve spool from air valve body by threading one air valve bolt into the end of the spool and gently sliding the spool out of the air valve body. Inspect seals for signs of wear and replace entire assembly if necessary. Use caution when handling air valve spool to prevent damaging seals. **NOTE:** Seals should not be removed from assembly. Seals are not sold separately.










Step 6

Remove pilot spool sleeve retaining snap ring on both sides of center section with snap ring pliers.

Step 7

Remove pilot spool sleeve from center section.





Step 8

With O-ring pick, gently remove the O-ring from the opposite side of the center hole cut on the spool. Gently remove the pilot spool from sleeve and inspect for nicks, gouges or other signs of wear. Replace pilot sleeve assembly or outer sleeve O-rings if necessary. During reassembly never insert the pilot spool into the sleeve with the center cut side first, this end incorporates the urethane O-ring and will be damaged as it slides over the ports cut in the sleeve. **NOTE:** Seals should not be removed from pilot spool. Seals are not sold separately.


Step 9

Check center section Glyd™ rings for signs of wear. If necessary, remove Glyd™ rings with O-ring pick and replace.






SINGLE-POINT EXHAUST



Step 1

Remove the pilot exhaust muffler in the pilot bleed port located at the front of the center block. Install 1/4" NPT pipe plug (00-7010-08) into the bleed port.



Step 2

Optional: Install a single-point exhaust gasket (02-2621-52). The single-point air valve gasket can be purchased as a spare part or included with the purchase of a new Pro-Flo SHIFT pump.

REASSEMBLY HINTS AND TIPS

Upon performing applicable maintenance to the air distribution system, the pump can now be reassembled. Please refer to the disassembly instructions for photos and parts placement.

To reassemble the pump, follow the disassembly instructions in reverse order. The air distribution system needs to be assembled first, then the diaphragms and finally the wetted path. The applicable torque specifications are on this page.

The following tips will assist in the assembly process:

- Lubricate the air valve bore, center section shaft and pilot spool bore with NLGI grade 2 white EP bearing grease or equivalent.
- Clean the inside of the center section shaft bore to ensure no damage is done to new shaft seals.
- A small amount of NLGI grade 2 white EP bearing grease can be applied to the muffler and air valve gaskets to lubricate gaskets during assembly.
- Make sure that the exhaust port on the muffler plate is centered between the two exhaust ports on the center section.
- Stainless bolts should be lubed to reduce the possibility of seizing during tightening.

Maximum Torque Specifications	
Description	Torque
Air Valve	11.3 N·m (100 in-lb)
Dial Set Screw	11.3 N·m (100 in-lb)
Outer Pistons, All	47.1 N·m (30 ft-lb)
Top and Bottom Manifold	8.5 N·m (75 in-lb)
Liquid Chambers to Center Section	8.5 N·m (75 in-lb)





SHAFT SEAL INSTALLATION

Pre-Installation

After all the old seals have been removed, the inside of the bushing should be cleaned to ensure no debris is left that may cause premature damage to the new seals.

Installation

- To prevent damaging the inside surface of the new seal, wrap electrical tape around each leg of the needle-nose pliers. (Heat shrink tubing may also be used.)
- With a new seal in hand, place the two legs of the needle-nose pliers inside the seal ring. (See Figure A.)
- Open the pliers as wide as the seal diameter will allow, then with two fingers pull down on the top portion of the seal to form a kidney bean shape. (See Figure B.)
- Lightly clamp the pliers together to hold the seal into the kidney shape. Be sure to pull the seal into as tight of a kidney shape as possible. This will allow the seal to travel down the bushing bore with greater ease.
- 5. With the seal clamped in the pliers, insert the seal into the busing bore and position the bottom of the seal into the correct groove. When the bottom of the seal is seated in the groove, release the clamp pressure on the pliers. This will allow the seal to partially snap back to its original shape.
- 6. After removing the pliers, you will notice a slight bump in the seal shape. Before the seal can be resized properly, the bump in the seal should be removed as much as possible. This can be done with either a Phillips screwdriver or your finger. With the side of the screwdriver or your finger, apply light pressure to the peak of the bump. This pressure will cause the bump to be eliminated almost completely.
- Lubricate the edge of the shaft with NLGI grade 2 white EP bearing grease.
- Slowly insert the center shaft with a rotating motion. This will complete the resizing of the seal.
- 9. Repeat these steps for the remaining seals.

Tools

The following tools can be used to aid in the installation of the new seals:

- Needle-Nose Pliers
- Phillips Screwdriver
- Electrical Tape

Figure A





Figure B






SECTION 8

EXPLODED VIEW AND PARTS LIST

PS220/PS230 METAL



LW0367 REV. F

Model Description	ALL CIRCLED PART IDENTIFIERS ARE INCLUDED IN REPAIR KITS						
	Model Description	PS220/230/ AAAAA//	PS220/230/ WWAAA//	PS220/230/ SSAAA//	PS230/ HHAAA//		



EXPLODED VIEW AND PARTS LIST

Item	Description	Qtv	P/N	P/N	P/N	P/N
			Distribution Components			
1	Pro-Flo X Air Valve Assembly ¹	1		02-2030	-01	
2	O-Ring, End Cap (-126, Ø1.362 x Ø.103)	2	01-2395-52			
3	End Cap	2		01-2340	-01	
4	Screw, SHC, Air Valve (1/4"-20 x 3")	4		01-6001-	-03	
5	Muffler Plate, Pro-Flo X	1		02-3185	-01	
6	Gasket, Muffler Plate, Pro-Flo X	1		02-3502	-56	
7	Gasket, Air Valve, Pro-Flo X	1		02-2620	-56	
8	Center Section Assembly, Pro-Flo SHIFT ²	1		02-3138	-01	
9	Pilot Sleeve Assembly	1		02-3880	-99	
10	Pilot Spool Retaining O-Ring (-009. Ø.208 x Ø.070)	1		04-2650-49	9-700	
11	Shaft Seal	2		02-3210-5	5-225	
12	Retaining Ring	1		00-2650	-03	
13	Grounding Screw, (10-32 x 1/2") Self-Tapping	1		04-6345	-08	
14	Muffler, 3/4" MNPT	1		08-3510-	99R	
15	Muffler, 1/4" MNPT	1		04-3240	-07	
			etted Path Components			
16	Liquid Chamber	2	02-5015-01	02-5015-02	02-5015-03	02-5015-04
17	Inlet Manifold, Side Ported, 1" NPT	1	02-5095-01	02-5095-02	02-5095-03	
	Inlet Manifold, Side Ported, 1" BSPT	1	02-5096-01	02-5096-02	02-5096-03	
	Inlet Manifold, Center Ported, 1" NPT	1	02-5095-01-677	02-5095-02-677	02-5095-03-677	
	Inlet Manifold, Center Ported, 1" BSPT	1	02-5096-01-678	02-5096-02-678	02-5096-03-678	
	Inlet Manifold, ANSI Flange	1			02-5090-03	02-5090-04
	Inlet Manifold, DIN Flange	1			02-5091-03	02-5091-04
18	Discharge Manifold, Side Ported, 1" NPT	1	02-5035-01	02-5035-02	02-5035-03	
	Discharge Manifold, Side Ported, 1" BSPT	1	02-5036-01	02-5036-02	02-5036-03	
	Discharge Manifold, Center Ported, 3/4" NPT	1	02-5035-01-697	02-5035-02-697	02-5035-03-697	
	Discharge Manifold, Center Ported, 3/4" BSPT	1	02-5036-01-698	02-5036-02-698	02-5036-03-698	
	Discharge Manifold, Center Ported, 1" NPT	1	02-5035-01-677	02-5035-02-677	02-5035-03-677	
	Discharge Manifold, Center Ported, 1" BSPT	1	02-5036-01-678	02-5036-02-678	02-5036-03-678	
	Discharge Manifold, ANSI Flange	1			02-5030-03	02-5030-04
	Discharge Manifold, DIN Flange	1			02-5031-03	02-5031-04
19	Screw, HHC, 5/16"-18 x 1"	32		08-6180-0		
20	Washer, 5/16"	32			02-6	731-03
21	Washer, 5/16"	30	02-673			
	Hanging Tab	2	02-740			
22	Pipe Plug, 1" NPT	2	02-7010-01	02-7010-02	02-7010-03	
	Pipe Plug, 1" BSPT	2	02-7011-01	02-7011-02	02-7011-03	
	Valve Balls/Valve Seats/Valve O-rings/Manifold O-ring					
23	Ball, Valve	4		*		
24	O-ring, Manifold (-229, Ø2.359 x Ø.139)	4			1	
25	Valve Seat	4	02-1125-01	02-1125-08	02-1125-03	02-1125-04
26	O-ring, Valve Seat (-224, Ø1.734 x Ø.139)	4		*		
		ull Stroke Ru	bber/TPE/PTFE/FSIPD Com			
27	Shaft	1		02-3810-		
28	Stud, 3/8"-16 x 1 1/4"	2	02-6150-08			
29	Disc Spring	2	02-6802-08			
30	Inner Piston	2	02-3701-01			
31	Diaphragm, Primary	2				
	Diaphragm, IPD Primary	2				
32	Diaphragm, Back-Up	2	00 4550 01	*	00 45-0 00	00 45-004
33	Outer Piston	2	02-4550-01	02-4550-02	02-4550-03	02-4550-04

^{*} See elastomer chart - Section 9

All boldface items are primary wear parts.

ELASTOMER OPTIONS

MATERIAL	DIAPHRAGMS (2)	FULL-STROKE DIAPHRAGMS (2)	FULL-STROKE BACK-UP DIAPHRAGMS (2)	FULL-STROKE IPD DIAPHRAGMS (2)	VALVE BALLS (4)	VALVE SEATS (4)	VALVE SEAT O-RINGS (4)	MANIFOLD O-RINGS (4)
Polyurethane					02-1085-50		02-1205-50	02-1372-50
Neoprene	02-1010-51				02-1085-51		02-1205-51	02-1372-51
Buna-N	02-1010-52				02-1085-52		02-1205-52	70-1280-52
Bunalast™				02-1031-15				
FKM	02-1010-53				02-1085-53		02-1205-53	02-1372-53
EPDM	02-1010-54				02-1085-54		02-1205-54	02-1372-54
PTFE		02-1040-55			02-1085-55		02-1205-55	70-1280-55
Non-Food Grade Saniflex™				02-1031-46				
Saniflex™	02-1010-56		02-1065-56	02-1031-56	02-1085-56		02-1205-56	02-1372-56
Wil-Flex®	02-1010-58			02-1031-58	02-1085-58		02-1205-58	02-1372-58
Food Grade Wil-Flex®			02-1065-57					
Aluminum						02-1125-01		
Mild Steel						02-1125-08		
Alloy C						02-1125-04		
Stainless Steel						02-1125-03		

LW0368 Rev. J



NOTES



NOTES



NOTES

WILDEN

22069 Van Buren Street Grand Terrace, CA 92313-5651 USA P: +1 (909) 422 -1730 psgdover.com



Where Innovation Flows